

20929 Bridge Street, Southfield, MI 48033
4121 Brockton Drive SE, Grand Rapids, MI 49512
6200 Baron Drive, Bridgeport, MI 48722
6910 Treeline Drive, Suite A, Brecksville, OH 44141

Phone: (800) 589-6120 - Fax: (248) 354-3710 www.deppmann.com

July 27th 2009 ~ Monday Morning Minutes:

Laars NeoTherm Condensing Boiler Water Piping

Last week, this series of articles, outlined Primary Secondary Piping. Laars NeoTherm condensing high efficiency boilers uses primary secondary piping arraignments in their installation. Please refer to Laars manual 1218B before installing this product, since it contains complete instructions and safety precautions.

The NeoTherm may have a boiler mounted pump or a separate pump, supplied by others. This is the primary pump and is used to keep a constant flow of water though the boiler for a given temperature difference. If the flow rate is outside the design specifications of Laars, there will be operational problems or damage to the boiler. As an example, the chart below shows a 24 GPM in a 500,000 BTUH input Neo with a 40°F Δ T and 47 GPM for a 20°F Δ T requirement.

	Temperature Rise in °F									
	20°F		25°F		30°F		35°F		40°F	
	Flow	H/L	Flow	H/L	Flow	H/L	Flow	H/L	Flow	H/L
Size	gpm	feet	gpm	feet	gpm	feet	gpm	feet	gpm	feet
285	27	25.5	22	17.5	18	14	15	10.5	13	8
399	38	28	31	20	25	14.5	22	11	19	9
500	47	24	38	16	32	12	27	9	24	8

Table 1: Flow rate chart from Laars document 1217D for NeoTherm Boilers

When piping these condensing boilers, it is important to use primary secondary piping and keep the pipe length to a minimum. This assures there is no affect on the boiler flow (primary), as the system flow rate (secondary) changes. In multiple boiler systems, it is advantageous to pipe condensing boilers in such a way that all boilers see the lowest inlet temperature. The lower the inlet temperature to the boiler, the higher the efficiency will be.




Figure 1: Multiple boiler piping arrangement from Laars 1218B manual

There are two close tees (12" apart or less) at the secondary piping. Each boiler receives the cooler return water for maximum efficiency. The primary piping is reverse return to assist in balancing the flow to each boiler.

In addition, Laars recommends the maximum piping distance from the piping takeoffs at the secondary system to the boilers be 15 feet (30 feet of total pipe) at the boiler connection pipe size. Contact R.L Deppmann or your local Laars representative for more specific piping questions based on your Laars NeoTherm application.



Thank you for using products sold by R. L. Deppmann Company in Michigan and Ohio!

Disclaimer: R. L. Deppmann and it's affiliates can not be held liable for issues caused by use of the information on this page. While the information comes from many years of experience and can be a valuable tool, it may not take into account special circumstances in your system and we therefore can not take responsibility for actions that result from this information. Please feel free to contact us if you do have any questions.