

Monday, June 20, 2016

# Bell and Gossett Part Load Efficiency Value

The last three Monday Morning Minutes have introduced the U.S. Department of Energy 2020 pump standards. The Standard looks at efficiency of pumps equally at various percentages of design GPM. The HVAC and Plumbing engineer know that pumps operate at less than design most of the time, but certainly not in equal percentages.

This article begins a series on a better way to evaluate pump life cycle costs and operating pump efficiency—the part load efficiency value.

When we look at part load operation, the Air-Conditioning, Heating, and Refrigeration Institute provides a good starting point with chillers by providing the AHRI Standard 550/590.

The standard provides a chiller rating, referred to as Integrated Part Load Value (IPLV). This rating is based on the "load" of the chillers. Realizing that this is a standard that engineers are familiar with, Bell and Gossett introduced a new term for the pumping

industry: PLEV or part load efficiency value.

Similar to IPLV, this efficiency rating for pumps looks not at part load, but at part flow. It's different, but relevant and easy to calculate when selecting pumps. PLEV takes a weighted average of the efficiency of a variable speed pump. As the flow rate drops, the speed drops, following a control curve starting at 0

#### Bell & Gossett "PLEV"

Part Load Efficiency Value for pumps

PLEV Formula Weighting Factors & Water Pump Flow Rates								
	Weighting	Pump Flow Rate	Pump kw	Run Point	Pump Efficiency	Operating Hours		
	1%	100%		А				
	42%	75%		В				
	45%	50%		С				
	12%	25%		D				
Pump PLEV = $\frac{1}{\frac{1\%}{A} + \frac{42\%}{B} + \frac{45\%}{C} + \frac{12\%}{D}}$ expressed in blended efficiency								

Based on 30% control head

GPM at 30% of the design head in feet.

PLEV weighs the pump efficiency of 100%, flow rate 1% of the time, efficiency at 75% of design flow rate 42% of the time, efficiency at 50% of design flow 45% of the time, and finally efficiency at 25% of design flow rate 12% of the time. The formula is shown below.

## **Example of Part Load Efficiency Value**

Let's assume a pump has a capacity of 2800 GPM at 100 feet. We've picked our pump and based operating expenses on the PLEV load profile. Our annual operating costs can be calculated as shown in Table 2.



Load	Hours	Flow GPM	Head Feet	RPM	Pump Eff.	BHP	Drive/ Motor Eff.	kWHR	Cost/day	Wire/Water Eff
25%	2.88	700.0	34.4	955	57.90	10.49	89.60	25.15	\$2.51	51.9%
50%	10.80	1,400.0	47.5	1152	78.17	21.47	89.28	193.63	\$19.36	69.8%
75%	10.08	2,100.0	69.3	1438	83.55	43.98	88.55	373.37	\$37.34	74.0%
100%	0.24	2,800.0	99.9	1766	85.01	83.05	87.71	16.95	\$1.69	74.6%

Variable Speed Operating Cost						
Total Kilowatt Hours = 222,323.0	Cost per kwhr = \$0.10					
Total Hours per Year = 8,760	Annual Operating Cost = \$22,232.30					

First Page

## np head = 30 feet



Notice that this calculation is based on 30 feet of control head. Again, it is absolutely critical that we

#### Control head is 30% of pump head = 30 feet

recognize that there will always be some constant head requirement. No pumping system with 2-way valves is ever 100% variable! If we erroneously assume otherwise, then the actual operating cost of our system will not reflect our predictions. In fact, we will have grossly underestimated.

To help illustrate this point, we've calculated the annual operating cost for the same system as above, based on zero control head and 100% of variable flow, below. Notice the operating cost is much lower than it was when we had 30 feet of control head — \$22,232 vs. \$15,254. That's almost \$7,000 missed in operating cost analysis which no one wants.



Using the PLEV as a guide for selecting pumps for today's variable speed systems is a good way to approximate operating cost and compare efficiencies of different pump selections over a range of operating points. You may replace the control

Load	Hours	Flow GPM	Head Feet	RPM	Pump Eff.	BHP	Drive/ Motor Eff.	kWHR	Cost/day	Wire/Water Eff
25%	2.88	700.0	7.2	467	84.10	1.51	83.62	3.89	\$0.39	70.3%
50%	10.80	1,400.0	25.8	894	84.83	10.76	89.61	96.71	\$9.67	76.0%
75%	10.08	2,100.0	56.9	1331	84.95	35.49	88.82	300.31	\$30.03	75.5%
100%	0.24	2,800.0	100.3	1769	84.99	83.43	87.70	17.03	\$1.70	74.5%

Variable Speed Operating Cost								
Total Kilowatt Hours = 152,546.7	Cost per kwhr = \$0.10							
Total Hours per Year = 8,760	Annual Operating Cost = \$15,254.67							

First Page



### Control head at 0% of pump head = 0 feet

head with the actual

value you calculated. If you're unsure of the exact amount of control head, we recommend plugging in 30 percent of the total pump head for a quick analysis.

Next week we will examine PLEV, it's use, and specification options.